



C E R T I F I C A T E

Certificate registration number: : G3.1507.039.1.C

Certificate holder: ATMEL Spain S.A.U.

Platform designation: ATPL250A,
Hardware version motherboard: ATPL250AMB_v1, daughterboard: ATPLCOUP006_v1,
Firmware version 1.1.2

Certification date: July 9th, 2015

This certificate indicates the above mentioned platform successfully completed certification testing with regards to the reference specification ITU G.9903 (02-2014) plus the changes listed in the annex to this certificate. The optional feature coherent mode of the G3-PLC protocol is also covered by this certification.

The certificate applies to certification profile FCC Multipurpose Worldwide and the device was configured as a PAN-Device.

Test cases have been performed as described in the test report referred to below. This certificate is granted on account of tests conducted by Laboratoire des Applications Numériques (LAN) in Tauxigny, France in June 2015. The results and remarks can be found in the complete test report.

Applied tests	Performed by	Document evidence
Conformance and interoperability testing according to the test specification referenced by the test report	Laboratoire des Applications Numériques (LAN)	TR_LAN15AF031

The device tested is a G3-PLC platform: a solution providing an implementation of the G3-PLC specification. This certificate is valid from July 9th, 2015.


The certificate is only applicable to the platform described above and permits the use of the G3-PLC™ logo as laid down in the G3-PLC logo license agreement. The certificate may only be reproduced in full.

This certificate does not imply assessment of the production. This certificate shall not be defined, or used as a guarantee covering quality of a product which includes G3-PLC. The liability of the Alliance and the test laboratory or any of her representatives is excluded for any damages or losses of the certified company.

Paris, July 9th, 2015

For the G3-PLC Alliance:


Marc Bouillot
 Chairman



Madeleine Francillard
Chair Certification Program





Annex 1: Reference Version for Certification

The reference version for this certificate is published in 'Narrowband OFDM PLC specifications for G3-PLC network, October 2014'.

The reference version for this certification is:

ITU-T G.9903 (02-2014)

- + CCTT #24-25-30: Implementation of MAC security (anti-replay) solution F1
- + CCTT #61 : ADPM-Buffer behavior clarification
- + CCTT #143: AC Phase Detection v2
- + CCTT #144: Hop Limit usage during route repair v3
- + CCTT #145: Value of RCoord when the node is at adpMaxHops hops from the coordinator
- + CCTT #146: Pilot tone generation
- + CCTT #147: Link-cost computation for Path discovery v2
- + CCTT #148: Path discovery frame routing v3
- + CCTT #152: Scrambler reset
- + CCTT #154: Clarification of PANCount and PANDescriptor
- + CCTT #156: Clarification of ADPM-NETWORK-STATUS.indication
- + CCTT #157: Interleaver Equation v2
- + CCTT #158: Unicast Routing Process
- + CCTT #159: Correct the windowing function description
- + CCTT #160: Clarify 16QAM quantisation and optionality
- + CCTT #161: Correct aMaxFrameSize and aMinFrameSize for FCC/ARIB bandplans
- + CCTT #162: Interleaver co-prime number clarification v2
- + CCTT #163: CRC5 and CRC8 packing order
- + CCTT #164: Route Repair v2
- + CCTT #165: Clarification Neighbour Table v2
- + CCTT #167: HOP COUNT metric identifier v2
- + CCTT #169: Clarification on PLME_GET v4
- + CCTT #170: Clarification to Frame Counter Handling Mechanism v2
- + CCTT #173: Clarification of LOADng mechanism used to detect bidirectional links



Annex 2: Protocol Implementation Conformance Statement (PICS)

Feature implementation statement

Name	Value	Description
BAND_PLAN	FCC	Indicate the band-plan supported by the device.
FEATURE_PAN_COORDINATOR	FALSE	Indicate if the device is a PAN-Coordinator (true) or a normal device (false)
FEATURE_COHERENT_MODULATION	TRUE	Indicate if coherent modulation is supported
FEATURE_EAP_SERVER	FALSE	Indicate if an EAP-PASK server is implemented by the DUT. Apply only if FEATURE_PAN_COORDINATOR = true
FEATURE_D8PSK_MODULATION	TRUE	True / False
FEATURE_ROUTING	TRUE	Indicate if the routing is implemented by the IUT
FEATURE_SECURITY	F1	Indicate the security implemented by the device. Possible values are: F1, F2.
FEATURE_ACTIVE_SCAN	TRUE	Indicate if the active scan process is done by the IUT after power-up

G3-PLC

CERTIFIED

FCC

Annex 3: Copy of test report cover sheet



G3-PLC Certification Test Report

ATMEL

ATPL250A

LAN15AF031

Ed.00

July 6, 2015

Passive

G3-PLC
Alliance

G3-PLC Platform Certification Test Report


Vendor Name **ATMEL**
Model Name **ATPL250A**
Serial N° **14090880091**
HW version **MB: ATPL250AMB_v1 DB: ATPLCOUP006_v1**
FW version **v1.1.2**

Test Report # **TR_LAN15AF031 Ed.00**
Date **July 6, 2015**

CONF tests specification **version 0.14, 19/11/2014**
CONF tests suite **version 1.9, 12/12/2014**
IOT tests specification **version 0.6, 12/12/2014**
IOT tests suite **version 1.3.1, 20/01/2015**

Test Tool **version 1.5**
Tester Modem **version 1.03**
Certification Test Procedures **version 1.4, 10/06/2015**

Certification Profile **C (FCC)**
Role **PAN Device**
Overall Verdict **PASS**



Initiation	Date	Description of modification	Ed.
Order DIOUF	July 6, 2015	Creation	00
Name	Realised by Order DIOUF	Checked by Vincent BUCHOUX	Approved by Thierry DOLIGEZ
Date	July 6, 2015	July 6, 2015	July 6, 2015
Sign			

This is a copy of the test report produced in the context of a certification process and must not be used for any other purpose.

This report contains a description of the approval as certified and no samples submitted to the laboratory. The results in this report are only valid for the device tested and only if they have been approved by the manufacturer. It is the responsibility of the manufacturer to ensure that the test results are valid for the device tested.