



C E R T I F I C A T E

Certificate registration number: G3.1511.056.1.A2

Certificate holder: Texas Instruments Inc.

Platform designation: TMDSPCKITV4-CEN,
Hardware version motherboard: SOMPLC-DOCKv1 rev4, daughterboard: F28PLC84,
Firmware version v7.7.7.6

Certification date: November 20th, 2015

This certificate indicates the above mentioned platform successfully completed certification testing with regards to the reference specification ITU G.9903 (02-2014) plus the changes listed in an annex to this certificate. The optional feature coherent mode of the G3-PLC protocol is also covered by this certification.

The certificate applies to certification profile Metering Cenelec A and the device was configured as a PAN-Device.

Test cases have been performed as described in the test report referred to below. This certificate is granted on account of tests conducted by Laboratoire des Applications Numériques (LAN) in Tauxigny, France in November 2015. The results and remarks can be found in the complete test report.

Applied tests	Performed by	Document evidence
Conformance and interoperability testing according to the test specification referenced by the test report	Laboratoire des Applications Numériques (LAN)	LAN15AF075

The device tested is a G3-PLC platform: a solution providing an implementation of the G3-PLC specification. This certificate is valid from November 20th, 2015.


The certificate is only applicable to the platform described above and permits the use of the G3-PLC™ logo as laid down in the G3-PLC logo license agreement. The certificate may only be reproduced in full.

This certificate does not imply assessment of the production. This certificate shall not be defined, or used as a guarantee covering quality of a product which includes G3-PLC. The liability of the Alliance and the test laboratory or any of her representatives is excluded for any damages or losses of the certified company.

Paris, November 20th, 2015

For the G3-PLC Alliance:


Bernard Lassus
Chairman



Madeleine Francillard
Chair Certification Program





Annex 1: Reference Version for Certification

The reference version for this certificate is published in 'Narrowband OFDM PLC specifications for G3-PLC network, April 2015'.

The reference version for this certification is:

ITU-T G.9903 (02-2014)

- + CCTT #24-25-30: Implementation of MAC security (anti-replay) solution F1
- + CCTT #61: ADPM-Buffer behavior clarification
- + CCTT #143: AC Phase Detection v2
- + CCTT #144: Hop Limit usage during route repair v3
- + CCTT #145: Value of RCCoord when the node is at adpMaxHops hops from the coordinator
- + CCTT #146: Pilot tone generation
- + CCTT #147: Link-cost computation for Path discovery v2
- + CCTT #148: Path discovery frame routing v3
- + CCTT #152: Scrambler reset
- + CCTT #154: Clarification of PANCount and PANDescriptor
- + CCTT #156: Clarification of ADPM-NETWORK-STATUS.indication
- + CCTT #157: Interleaver Equation v2
- + CCTT #158: Unicast Routing Process
- + CCTT #159: Correct the windowing function description
- + CCTT #160: Clarify 16QAM quantisation and optionality
- + CCTT #161: Correct aMaxFrameSize and aMinFrameSize for FCC/ARIB bandplans
- + CCTT #162: Interleaver co-prime number clarification v2
- + CCTT #163: CRC5 and CRC8 packing order
- + CCTT #164: Route Repair v2
- + CCTT #165: Clarification Neighbour Table v2
- + CCTT #167: HOP COUNT metric identifier v2
- + CCTT #169: Clarification on PLME_GET v4
- + CCTT #170: Clarification to Frame Counter Handling Mechanism v2
- + CCTT #172: Windowing in coherent mode
- + CCTT #173: Clarification of LOADng mechanism used to detect bidirectional links
- + CCTT #174: Avoiding duplicated MAC packets
- + CCTT #175: LOADng - subsequent RREP generation
- + CCTT #176: Link cost function of LQI v3
- + CCTT #177: Broadcast routing - filtering frames on the source
- + CCTT #178: Coexistence of G3-PLC with other PLC technologies v3
- + CCTT #179: RREP Filtering v3
- + CCTT #181: Route Repair v2

Annex 2: Protocol Implementation Conformance Statement (PICS)

Feature implementation statement

Name	Value	Description
BAND_PLAN	CENELEC A	Indicate the band-plan supported by the device.
FEATURE_PAN_COORDINATOR	FALSE	Indicate if the device is a PAN-Coordinator (true) or a normal device (false).
FEATURE_COHERENT_MODULATION	TRUE	Indicate if coherent modulation is supported.
FEATURE_EAP_SERVER	FALSE	Indicate if an EAP-PASK server is implemented by the DUT. Apply only if FEATURE_PAN_COORDINATOR = true.
FEATURE_D8PSK_MODULATION	TRUE	True / False
FEATURE_ROUTING	TRUE	Indicate if the routing is implemented by the IUT.
FEATURE_SECURITY	F1	Indicate the security implemented by the device. Possible values are: F1, F2.
FEATURE_ACTIVE_SCAN	TRUE	Indicate if the active scan process is done by the IUT after power-up.
FEATURE_PREAMBLE_COEXISTENCE_MECHANISM	FALSE	Indicate if the preamble-based coexistence mechanism is used by the IUT.

Annex 3: Copy of test report cover sheet



G3-PLC Certification Test Report

Tested Instruments: TMDSPCKITV4-CEN (see Annex 3) / SOMPLC-DOCKv1 rev4
Daughter Board: F28PLC84 / v7.7.7.6

LAN15AF075 Ed.00 November 17, 2015 Page 1/05



G3-PLC Platform Certification Test Report

Vendor Name: **Texas Instruments**
 Model Name: **TMDSPCKITV4-CEN**
 Serial N°: **00200031**
 HW version: **Mother Board : SOMPLC-DOCKv1 rev4
Daughter Board: F28PLC84**
 FW version: **v7.7.7.6**

Test Report #: **TR_LAN15AF075 Ed.00**
 Date: **November 17, 2015**

CONF Tests Specification: **version 0.19. 01/09/2015**
 CONF Tests Suite: **version 2.1. 10/2015**
 IDT Tests Specification: **version 0.7. 21/04/2015**
 IDT Tests Suite: **version 2.1. 10/2015**

Test Tool: **version 1.7**
 Tester Modem: **version 1.09**
 Certification Test Procedures: **version 1.4 10/06/2015**

Certification Profile: **A (CENELEC A)**
 Role: **PAN Device**
 Overall Verdict: **PASS**



Initiation	Date	Description of modification	Ed.
Draw DIOUP	November 17, 2015	Creation	00
Name	Realized by	Checked by	Approved by
Date	November 17, 2015	November 17, 2015	November 17, 2015
Sign			

The current report and the test results contained in this document are given for information only and could not be relied on for any legal action in any manner.
 This report contains a statement of the applicable services and its associated conditions. The results in this report relate only to the test system and were obtained in the defined hardware, the initial quantity of samples and the time of the report. It should be noted that technical hardware or software modifications on the system may affect the results reported in this document.