



C E R T I F I C A T E

Certificate registration number: G3.2005.389.2.D4

Certificate holder: B&C Project

Product designation: SLT-P,
Hardware version V1.1, Firmware version 4.4.9 - v1390B5EC - r1.6

Certification date: May 28th, 2019

This certificate indicates the above mentioned product successfully completed certification testing with regards to the reference specification ITU G.9903 (08-2017) plus the changes listed in an annex to this certificate. The optional feature coherent mode of the G3-PLC protocol is also covered by this certification.

The certificate applies to certification profile CENELEC B and the device was configured as a PAN-Device.

Test cases have been performed as described in the test report referred to below. This certificate is granted on account of tests conducted by Laboratoire des Applications Numériques (LAN) in Tauxigny, France in November 2019. The results and remarks can be found in the complete test report.

Applied tests	Performed by	Document evidence
Conformance, interoperability and performance testing according to the test specification referenced by the test report	Laboratoire des Applications Numériques (LAN)	LAN20AF014

The device tested is a G3-PLC CENELEC B 1-phase end-device. The product is equipped with the G3-PLC certified platform ST8500 with certificate no. G3.1910.320.1.D4. The Protocol Implementation Conformance Statement in the Annex includes the PICS related to performance and is an integral part of this certificate. This certificate is valid from May 28th, 2019.

The certificate is only applicable to the product described above and permits the use of the G3-PLC™ logo as laid down in the G3-PLC logo license agreement.

This certificate does not imply assessment of the production. This certificate shall not be defined, or used as a guarantee covering quality of a product which includes G3-PLC. The liability of the Alliance and the test laboratory or any of her representatives is excluded for any damages or losses of the certified company.

Paris, May 28th, 2019

For the G3-PLC Alliance:


Marc Delandre
Chairman


389

Madeleine Francillard
Chair Certification Program





Annex 1: Reference Version for Certification


The reference version for this certification is ITU-T G.9903 (08-2017)
+ CCTT #210: Number of tones per sub-band for CENELEC B
+ CCTT #211: Clarification and corrections for CENELEC-B band

Two handwritten signatures in blue ink, one to the left and one to the right, positioned above the footer.

Annex 2: Protocol Implementation Conformance Statement (PICS)

Feature implementation statement

Name	Value	Description
BAND_PLAN	CENELEC B	Indicate the band-plan supported by the device.
FEATURE_PAN_COORDINATOR	FALSE	Indicate if the device is a PAN-Coordinator (true) or a normal device (false).
FEATURE_COHERENT_MODULATION	TRUE	Indicate if coherent modulation is supported.
FEATURE_EAP_SERVER	FALSE	Indicate if an EAP-PASK server is implemented by the DUT. Apply only if FEATURE_PAN_COORDINATOR = true.
FEATURE_D8PSK_MODULATION	TRUE	True / False
FEATURE_ROUTING	TRUE	Indicate if the routing is implemented by the IUT.
FEATURE_SECURITY	F1	Indicate the security implemented by the device. Possible values are: F1, F2.
FEATURE_ACTIVE_SCAN	TRUE	Indicate if the active scan process is done by the IUT after power-up.
FEATURE_PREAMBLE_COEXISTENCE_MECHANISM	FALSE	Indicate if the preamble-based coexistence mechanism is used by the IUT.



Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (1/2)

The device tested is a G3-PLC CENELEC B 1-phase end-device. Testing was performed on phase 1.

Operating voltage applied for certification testing was 230V / 50Hz.

Name	Value	Unit	Description
<p>PICS related to performance are available through vendor only.</p>			



Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (2/2)

Name	Value	Unit	Description
<p>PICS related to performance are available through vendor only.</p>			



Annex 3: Copy of test report cover sheet



G3-PLC Certification Test Report			
B&C Project	SLT-P HW:V1.1 FW: 4.4.9 - v1390B5EC - r1.6		
LAN20AF014	Ed.01	May 15, 2020	Page 1/44



G3-PLC Product Certification Test Report

Vendor Name **B&C Project**
 Model Name **SLT-P**
 Serial N° **T_0000036**
 HW version **V1.1**
 FW version **4.4.9 - v1390B5EC - r1.6**

Test Report # **TR_LAN20AF014 Ed.01**
 Date **May 15, 2020**

CONF Tests Specification	version 0.30.	03/12/2018
CONF Tests Suite	version 2.9.p1.	09/2019
IOT Tests Specification	version 0.13.	28/12/2018
IOT Tests Suite	version 2.6.p1.	09/2019
PERF Tests Specification	version 0.27.	05/03/2019
PERF Tests Suite	version 2.9.p1.	09/2019

Test Tool **version 2.3**
 Tester Modem **version 2.0**
 Certification Test Procedures **version 1.14** **21/09/2019**

Certification Profile **(CENELEC B)**
 Role **End Device**
 Overall Verdict **PASS**



The results reported in this test report are based on the tests done on the P MAE and reported in the test report Ref. TR_LAN19AF077 Ed.00 (according to the manufacturer, both products are identical).

Initiation	Date	Description of modification	Ed.
Omar DIOUF	November 15, 2019	Creation	00
Omar DIOUF	May 15, 2020	Picture updated	01

Name	Realised by	Checked by	Approved by
	Omar DIOUF	Vincent BUCHOUX	Thierry DOLIGEZ
Date	May 15, 2020	May 15, 2020	May 15, 2020
Sign			

The current report and the test results produced in this current are given for information only and must not be relied on by any third person for any reason.
 This report contains an assessment of the apparatus carried out on samples submitted to the laboratory. The results in this report relate only to the items tested and were obtained in the period between the initial receipt of samples and the issue of the report. It should be noted that technical hardware or software modifications on the apparatus may impact the results reported in this document.