



C E R T I F I C A T E

Certificate registration number: G3.2204.502.2.A5

Certificate holder: Chongqing Huahong Metering Co., Ltd.

Product designation: DTSY1311,
Hardware version T.1.1.0, Firmware version ESG3SD-V000201

Certification date: April 2nd, 2022

This certificate indicates the above mentioned product successfully completed certification testing with regards to the reference specification ITU G.9903 (08-2017).

The certificate applies to certification profile CENELEC A and the device was configured as a PAN-Device.

Test cases have been performed as described in the test report referred to below. This certificate is granted on account of tests conducted by TÜV Rheinland in Yokohama, Japan in January 2022. The results and remarks can be found in the complete test report.

Applied tests	Performed by	Document evidence
Conformance, interoperability and performance testing according to the test specification referenced by the test report	TÜV Rheinland Japan	JP22C47N 001

The device tested is a G3-PLC CENELEC A 3-phase meter. The meter is equipped with the G3-PLC certified platform ESPLC-CEN with certificate no. G3.2102.427.1.A4. The Protocol Implementation Conformance Statement in the Annex includes the PICS related to performance and is an integral part of this certificate. This certificate is valid from April 2nd 2022.

The certificate is only applicable to the product described above and permits the use of the G3-PLC™ logo as laid down in the G3-PLC logo license agreement.

This certificate does not imply assessment of the production. This certificate shall not be defined, or used as a guarantee covering quality of a product which includes G3-PLC. The liability of the Alliance and the test laboratory or any of her representatives is excluded for any damages or losses of the certified company.

Paris, April 2nd 2022

For the G3-PLC Alliance:


Marc Delandre
Chairman


502

Madeleine Francillard
Chair Certification Program

G3-PLC
Alliance

Annex 1: Protocol Implementation Conformance Statement (PICS)

Feature implementation statement

Name	Value	Description
BAND_PLAN	CENELEC A	Indicate the band-plan supported by the device.
FEATURE_PAN_COORDINATOR	FALSE	Indicate if the device is a PAN-Coordinator (true) or a normal device (false).
FEATURE_COHERENT_MODULATION	FALSE	Indicate if coherent modulation is supported.
FEATURE_EAP_SERVER	FALSE	Indicate if an EAP-PASK server is implemented by the DUT. Apply only if FEATURE_PAN_COORDINATOR = true.
FEATURE_D8PSK_MODULATION	TRUE	True / False
FEATURE_ROUTING	TRUE	Indicate if the routing is implemented by the IUT.
FEATURE_SECURITY	F1	Indicate the security implemented by the device. Possible values are: F1, F2.
FEATURE_ACTIVE_SCAN	TRUE	Indicate if the active scan process is done by the IUT after power-up.
FEATURE_PREAMBLE_COEXISTENCE_MECHANISM	FALSE	Indicate if the preamble-based coexistence mechanism is used by the IUT.





Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (1/2)

The device tested is a G3-PLC CENELEC A 3-phase meter communicating on 1-phase. Testing was performed on phase 1.

Operating voltage applied for certification testing was 3AC400V (3x230V L-N)/50Hz.

Name	Value	Unit	Description
<p>PICS related to performance are available through vendor only.</p>			



Annex 2: Protocol Implementation Conformance Statement (PICS)




PICS related to performance (2/2)

Name	Value	Unit	Description
<p>PICS related to performance are available through vendor only.</p>			

Annex 3: Copy of test report cover sheet

Prüfbericht - Produkte
Test Report - Products



Prüfbericht-Nr.: <i>Test report no.:</i>	JP22C47N 001	Auftrags-Nr.: <i>Order no.:</i>	150258456 10 Seite 1 von 53 Page 1 of 53
Kunden-Referenz-Nr.: <i>Client reference no.:</i>	DTSY1311	Auftragsdatum: <i>Order date:</i>	2022-03-11
Auftraggeber: <i>Client:</i>	Holley Technology Ltd No.181 Wuchang Avenue, Yuhang District Hangzhou 310023, China		
Prüfgegenstand: <i>Test item:</i>	Smart Meter CENELEC A		
Bezeichnung / Typ-Nr.: <i>Identification / Type no.:</i>	DTSY1311 (Chongqing Huahong Metering Co., Ltd.)		
Auftrags-Inhalt: <i>Order content:</i>	G3PLC		
Prüfgrundlage: <i>Test specification:</i>	G3 PLC Conformance Tests Specification v0.32 G3-PLC 1-to-1 Interoperability Tests Specification v0.13 G3-PLC Performance Test Suite Specification v0.27 G3-PLC Certification Test Procedures v2.0		
Wareneingangsdatum: <i>Date of sample receipt:</i>	2022-01-10 (original model)		
Prüfmuster-Nr.: <i>Test sample no.:</i>	A003198883-002 (original model)		
Prüfzeitraum: <i>Testing period:</i>	2022-01-12 – 2022-01-14 (original model)		
Ort der Prüfung: <i>Place of testing:</i>	4-25-2 Kita-Yamata, Tsuzuki-ku Yokohama 224-0021, Japan		
Prüflaboratorium: <i>Testing laboratory:</i>	TÜV Rheinland Japan Ltd.		
Prüfergebnis*: <i>Test result*:</i>	Pass		
geprüft von: <i>tested by:</i>	 Martin Zietz	genehmigt von: <i>authorized by:</i>	 Shuji Saito
Datum: <i>Date:</i>	2022-03-25	Ausstellungsdatum: <i>Issue date:</i>	2022-03-25
Stellung / Position:	Tester	Stellung / Position:	Reviewer
Sonstiges / Other: The product which this report covers is, according to the declaration of the client, identical to the product in report JP2229XW 001. The company name and the product name DTSY541 changed to the above mentioned. All administrative and test data in this report are taken from report JP2229XW 001 without additional testing.			
Zustand des Prüfgegenstandes bei Anlieferung: <i>Condition of the test item at delivery:</i>		Prüfmuster vollständig und unbeschädigt <i>Test item complete and undamaged</i>	
* Legende: P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet * Legend: P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested			
Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens. <i>This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</i>			