



# C E R T I F I C A T E

**Certificate registration number:** G3.2308.582.2.C6

**Certificate holder:** Qingdao iTechene Technologies Co., Ltd.

**Product designation:** TD12

Hardware version TD12-V1.0, Firmware version ESG3SC-V003012

**Certification date:** August 23<sup>rd</sup> 2023

This certificate indicates the above-mentioned product successfully completed certification testing with regards to the G3-Alliance reference specification 06/2021.

The device is certified for both G3-PLC and G3-Hybrid. The optional feature coherent mode of the G3 protocol is also covered by this certification. The certificate applies to certification profile FCC Multipurpose Worldwide and the device was configured as a PAN-Coordinator.

Test cases have been performed as described in the test report referred to below. This certificate is granted on account of tests conducted by TÜV Rheinland in Yokohama, Japan in August 2023. The results and remarks can be found in the complete test report.

Applied tests	Performed by	Document evidence
Conformance, interoperability and performance testing according to the test specification referenced by the test report	TÜV Rheinland Japan	JP23FGZA 001

The device tested is a G3-Hybrid FCC PLC+RF 3-phase data concentrator. The data concentrator is equipped with the G3-Hybrid certified platform ESPLC-FCC-HYB with certificate no. G3.2204.506.1.C6. The Protocol Implementation Conformance Statement in the Annex includes the PICS related to performance and is an integral part of this certificate. This certificate is valid from August 23<sup>rd</sup> 2023.

The certificate is only applicable to the product described above and permits the use of the G3-Hybrid™ logo as laid down in the logo license agreement.

This certificate does not imply assessment of the production. This certificate shall not be defined, or used as a guarantee covering quality of a product which includes G3-Hybrid. The liability of the Alliance and the test laboratory or any of her representatives is excluded for any damages or losses of the certified company.

Paris, August 23<sup>rd</sup> 2023

For the G3-PLC Alliance:

**Marc Delandre**  
Chairman


**Madeleine Francillard**  
Chair Certification Program



# Annex 1: Protocol Implementation Conformance Statement (PICS)

## Feature implementation statement

Name	Value	Description
BAND_PLAN	FCC	Indicate the band-plan supported by the device
BAND_PLAN_RF	863-870_SingleCarrier_Mode#1 863-870_SingleCarrier_Mode#2 865-868_SingleCarrier_Mode#1 865-868_SingleCarrier_Mode#2 870-876_SingleCarrier_Mode#1 870-876_SingleCarrier_Mode#2	Indicate the RF band plan(s) supported by the device
FEATURE_HYBRID_RF	TRUE	Indicate if Hybrid PLC&RF feature is supported
FEATURE_PAN_COORDINATOR	TRUE	Indicate if the device is a PAN-Coordinator (true) or a normal device (false)
FEATURE_COHERENT_MODULATION	TRUE	Indicate if coherent modulation is supported
FEATURE_EAP_SERVER	TRUE	Indicate if an EAP-PASK server is implemented by the DUT Apply only if FEATURE_PAN_COORDINATOR = true
FEATURE_D8PSK_MODULATION	TRUE	Indicate if D8PSK modulation is supported
FEATURE_ROUTING	TRUE	Indicate if the routing is implemented by the IUT
FEATURE_SECURITY	F1	Indicate the security implemented by the device. Possible values are: F1, F2
FEATURE_ACTIVE_SCAN	TRUE	Indicate if the active scan process is done by the IUT after power-up
FEATURE_PREAMBLE_COEXISTENCE_MECHANISM	FALSE	Indicate if the preamble-based coexistence mechanism is used by the IUT





# Annex 2: Protocol Implementation Conformance Statement (PICS)

## PICS related to performance (1/2)

The device tested is a G3-Hybrid FCC PLC+RF 3-phase data concentrator communicating on 3 phases. Testing was performed on phase 1.

Operating voltage applied for certification testing was 3AC380V (3x220V L-N) / 60Hz.

Name	Value	Unit	Description
<p>PICS related to performance are available through vendor only.</p>			









# Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (2/2)

Name	Value	Unit	Description
<p>PICS related to performance are available through vendor only.</p>			

## Annex 3: Copy of test report cover sheet

<b>Test Report – Products</b> <i>Prüfbericht - Produkte</i>		 <b>TÜVRheinland®</b>
<b>Test report no.:</b> <i>Prüfbericht-Nr.:</i>	<b>JP23FGZA 001</b>	<b>Order No.:</b> <i>Auftragsnr.:</i> 150278313 10 <span style="float: right;">Page 1 of 59 Seite 1 von 59</span>
<b>Client reference no.:</b> <i>Kunden-Referenz-Nr.:</i>	<b>TD12</b>	<b>Order date:</b> <i>Auftragsdatum:</i> 2023-05-19
<b>Client:</b> <i>Auftraggeber:</i>	Qingdao iTechene Technologies Co., Ltd., 8 Floor, Block A, International Innovation Park, No.1 Keyuanweiyi Rd, Laoshan District, Qingdao, 266061, P.R.China	
<b>Test item:</b> <i>Prüfgegenstand:</i>	Data Concentrator (FCC)	
<b>Identification / Type no.:</b> <i>Bezeichnung / Typ-Nr.:</i>	TD12	
<b>Order content:</b> <i>Auftrags-Inhalt:</i>	G3 Certification Test	
<b>Test specification</b> <i>Prüfgrundlage:</i>	G3-Alliance - Conformance Tests Suite Specification - v0.37 G3-Alliance - 1to1-PHY-Interoperability-Tests-Specification-v0.14 G3-Alliance - Performance Test Suite Specification - v0.27 G3-Certification Test Procedures version 6.02 G3-Alliance - Hybrid PLC&RF - Conformance Tests Suite Specification - v0.10 G3-Alliance - 1to1-PHY-RF-Interoperability-Tests-Specification-v0.7	
<b>Date of sample receipt:</b> <i>Wareneingangsdatum:</i>	2023-08-03	
<b>Test sample no.:</b> <i>Prüfmuster-Nr.:</i>	A003531665-002	
<b>Testing period:</b> <i>Prüfzeitraum:</i>	2023-08-09 - 2023-08-16	
<b>Place of testing:</b> <i>Ort der Prüfung:</i>	4-25-2 Kita-Yamata, Tsuzuki-ku Yokohama 224-0021, Japan	
<b>Testing laboratory:</b> <i>Prüflaboratorium:</i>	TÜV Rheinland Japan Ltd.	
<b>Test result*:</b> <i>Prüfergebnis*:</i>	Pass	
<b>tested by:</b> <i>geprüft von:</i>		<b>authorized by:</b> <i>genehmigt von:</i> 
<b>Date:</b> 2023-08-21 <i>Datum:</i>	Martin Zietz	<b>Issue date:</b> 2023-08-21 <i>Ausstellungsdatum:</i> Shuji Saito
<b>Position / Stellung:</b>	Tester	<b>Position / Stellung:</b> Reviewer
<b>Other:</b> <i>Sonstiges:</i>		
<b>Condition of the test item at delivery:</b> <i>Zustand des Prüfgegenstandes bei Anlieferung:</i>	Test item complete and undamaged Prüfmuster vollständig und unbeschädigt	
<small>* Legend: P(ass) = passed a.m. test specification(s) F(all) = failed a.m. test specification(s) N/A = not applicable N/T = not tested * Legende: P(ass) = entspricht o.g. Prüfgrundlage(n) F(all) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet</small>		
<b>This test report only relates to the above mentioned test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</b> <i>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</i>		
<small>TÜV Rheinland Japan Ltd., Global Technology Assessment Center 4-25-2 Kita-Yamata, Tsuzuki-ku Yokohama 224-0021, Japan Mail: g3plc@tuv.com · Web: www.tuv.com/</small>		