



C E R T I F I C A T E

Certificate registration number: G3.2312.593.2.C6

Certificate holder: Iskraemeco, d.d.

Product designation: IE.5-TD,
Hardware version 027.640.397.000, Firmware version 5.0

Certification date: December 15th 2023

This certificate indicates the above-mentioned product successfully completed certification testing with regards to the G3-Alliance reference specification 06/2021. The optional feature coherent mode of the G3 protocol is also covered by this certification.

The certificate applies to certification profile FCC Multipurpose Worldwide and the device was configured as a PAN-Device.

Test cases have been performed as described in the test report referred to below. This certificate is granted on account of tests conducted by Laboratoire des Applications Numériques (LAN) in Tauxigny, France in December 2023. The results and remarks can be found in the complete test report.

Applied tests	Performed by	Document evidence
Conformance, interoperability and performance testing according to the test specification referenced by the test report	Laboratoire des Applications Numériques (LAN)	LAN23AF018

The device tested is a G3-PLC FCC 3-phase meter. The meter is equipped with the G3-PLC certified platform ENV-EV8010-QFN56-1PHASE-A2 with certificate no. G3.2209.535.1.C6. The Protocol Implementation Conformance Statement in the Annex includes the PICS related to performance and is an integral part of this certificate. This certificate is valid from December 15th 2023.


The certificate is only applicable to the product described above and permits the use of the G3-PLC certification logo as laid down in the G3-Alliance logo license agreement.

This certificate does not imply assessment of the production. This certificate shall not be defined, or used as a guarantee covering quality of a product which includes G3-PLC. The liability of the Alliance and the test laboratory or any of her representatives is excluded for any damages or losses of the certified company.

Paris, December 15th 2023

For the G3-Alliance:


Marc Delandre
Chairman


593

Madeleine Francillard
Chair Certification Program

G3-Alliance



Annex 1: Protocol Implementation Conformance Statement (PICS)

Feature implementation statement

Name	Value	Description
BAND_PLAN	FCC	Indicates whether the band-plan supported by the device
BAND_PLAN_RF	N/A	Indicates whether the RF band plan(s) supported by the device
FEATURE_HYBRID_RF	FALSE	Indicates whether Hybrid PLC+RF feature is supported
FEATURE_PAN_COORDINATOR	FALSE	Indicates whether the device is a PAN-Coordinator (true) or a normal device (false)
FEATURE_COHERENT_MODULATION	TRUE	Indicates whether coherent modulation is supported
FEATURE_EAP_SERVER	FALSE	Indicates whether an EAP-PASK server is implemented by the DUT Apply only if FEATURE_PAN_COORDINATOR = true
FEATURE_D8PSK_MODULATION	TRUE	Indicates whether D8PSK modulation is supported
FEATURE_ROUTING	TRUE	Indicates whether the routing is implemented by the IUT
FEATURE_SECURITY	F1	Indicates whether the security implemented by the device. Possible values are: F1, F2
FEATURE_ACTIVE_SCAN	TRUE	Indicates whether the active scan process is done by the IUT after power-up
FEATURE_PREAMBLE_COEXISTENCE_MECHANISM	FALSE	Indicates whether the preamble-based coexistence mechanism is used by the IUT



Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (1/2)

The device tested is a G3-PLC FCC 3-phase meter communicating on phase 1.
Testing was performed on phase 1.

Operating voltage applied for certification testing was 3 x 230V/50Hz.

Name	Value	Unit	Description
<i>PICS related to performance are available through manufacturer only.</i>			




Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (2/2)

Name	Value	Unit	Description
<p>PICS related to performance are available through manufacturer only.</p>			

Annex 3: Copy of test report cover sheet



LANPARK
Expanding networks

G3-PLC Certification Test Report


Iskraemeco, d.d.	IE.5-TD HW:027.640.397.000 FW: 5.0
LAN23AF018	Ed.00
December 14, 2023	Page 1/47

G3-Alliance




G3-PLC Product Certification

Test Report

Vendor Name	Iskraemeco, d.d.		
Model Name	IE.5-TD		
Serial N°	20231469		
HW version	027.640.397.000		
FW version	5.0		
Test Report #	TR_LAN23AF018 Ed.00		
Date	December 14, 2023		
CONF Tests Specification	version 0.37.	18/01/2022	
CONF Tests Suite	version 2.14.	02/2022	
IOT Tests Specification	version 0.14.	11/11/2020	
IOT Tests Suite	version 2.7.	11/2021	
PERF Tests Specification	version 0.27.	05/03/2019	
PERF Tests Suite	version 2.14.	02/2022	
Test Tool	version 3.2		
Tester Modem	version 2.0.1		
Certification Test Procedures	version 6.04	06/09/2022	
Certification Profile	C (FCC)		
Role	Meter		
Overall Verdict	PASS		



Initiation	Date	Description of modification	Ed.
Omar DIOUF	December 14, 2023	Creation	00

	Realised by	Checked by	Approved by
Name	Omar DIOUF	Vincent BUCHOUX	Thierry DOLIGEZ
Date	December 14, 2023	December 14, 2023	December 14, 2023
Sign			

The current report and the test results produced in this current are given for information only and must not be relied on by any third person for any reason.

This report contains an assessment of the apparatus carried out on samples submitted to the laboratory. The results in this report relate only to the items tested and were obtained in the period between the initial receipt of samples and the issue of the report. It should be noted that technical hardware or software modifications on the apparatus may impact the results reported in this document.