



C E R T I F I C A T E

Certificate registration number: G3.2406.608.2.A6

Certificate holder: Landis+Gyr AG

Product designation: CR6 G3,
Hardware version V1.0, Firmware version mod12 V05.06.00

Certification date: June 7th 2024

This certificate indicates the above-mentioned product successfully completed certification testing with regards to the G3-Alliance reference specification 06/2021. The optional feature coherent mode of the G3 protocol is also covered by this certification.

The certificate applies to certification profile CENELEC A and the device was configured as a PAN-Coordinator.

Test cases have been performed as described in the test report referred to below. This certificate is granted on account of tests conducted by Laboratoire des Applications Numériques (LAN) in Tauxigny, France in February 2024. The results and remarks can be found in the complete test report.

Applied tests	Performed by	Document evidence
Conformance, interoperability and performance testing according to the test specification referenced by the test report	Laboratoire des Applications Numériques (LAN)	LAN22AF097

The device tested is a G3-PLC CENELEC A 3-phase Data Concentrator. The product is equipped with the G3-Alliance certified platform REL-G3PLC-CPX3+TRG with certificate no. G3.2205.513.1.A6. The Protocol Implementation Conformance Statement in the Annex includes the PICS related to performance and is an integral part of this certificate. This certificate is valid from June 7th 2024.

The certificate is only applicable to the product described above and permits the use of the G3-PLC logo as laid down in the G3-Alliance logo license agreement.

This certificate does not imply assessment of the production. This certificate shall not be defined, or used as a guarantee covering quality of a product which includes G3-PLC. The liability of the Alliance and the test laboratory or any of her representatives is excluded for any damages or losses of the certified company.

Paris, June 7th 2024

For the G3-Alliance:

Marc Delandre
Chairman


Madeleine Francillard
Chair Certification Program

G3-Alliance

Annex 1: Protocol Implementation Conformance Statement (PICS)

Feature implementation statement

Name	Value	Description
BAND_PLAN	CENELEC A	Indicates the band-plan supported by the device
BAND_PLAN_RF	N/A	Indicates the RF band plan(s) supported by the device
FEATURE_HYBRID_RF	FALSE	Indicates whether Hybrid PLC&RF feature is supported
FEATURE_PAN_COORDINATOR	TRUE	Indicates whether the device is a PAN-Coordinator (true) or a normal device (false)
FEATURE_COHERENT_MODULATION	TRUE	Indicates whether coherent modulation is supported
FEATURE_EAP_SERVER	TRUE	Indicates whether an EAP-PASK server is implemented by the DUT Applies only if FEATURE_PAN_COORDINATOR = true
FEATURE_D8PSK_MODULATION	TRUE	Indicates whether D8PSK modulation is supported
FEATURE_ROUTING	TRUE	Indicates whether routing is implemented by the IUT
FEATURE_SECURITY	F1	Indicates the security implemented by the device. Possible values are: F1, F2
FEATURE_ACTIVE_SCAN	TRUE	Indicates whether the active scan process is done by the IUT after power-up
FEATURE_PREAMBLE_COEXISTENCE_MECHANISM	FALSE	Indicates whether the preamble-based coexistence mechanism is used by the IUT





Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (1/2)

The device tested is a G3-PLC CENELEC A 3-phase data concentrator communicating on 3 phases. Testing was performed on phase 1.

Operating voltage applied for certification testing was 3 x 230V / 50Hz.

Name	Value	Unit	Description
<i>PICS related to performance are available through manufacturer only.</i>			

Annex 2: Protocol Implementation Conformance Statement (PICS)

PICS related to performance (2/2)

Name	Value	Unit	Description
<p>PICS related to performance are available through manufacturer only.</p>			

Annex 3: Copy of test report cover sheet



G3-PLC Certification Test Report


Landis+Gyr AG	CR6 G3 HW:V1.0 FW: mod12 V05.06.00
LAN22AF097	Ed.00
June 5, 2024	Page 1/47

G3-Alliance G3-PLC Product Certification Test Report

Vendor Name **Landis+Gyr AG**
 Model Name **CR6 G3**
 Serial N° **042474900009**
 HW version **V1.0**
 FW version **mod12 V05.06.00**

Test Report # **TR_LAN22AF097 Ed.00**
 Date **June 5, 2024**

CONF Tests Specification	version 0.37.	18/01/2022
CONF Tests Suite	version 2.14.	02/2022
IOT Tests Specification	version 0.14.	11/11/2022
IOT Tests Suite	version 2.7.	11/2021
PERF Tests Specification	version 0.27.	05/03/2019
PERF Tests Suite	version 2.14.	02/2022
Test Tool	version 3.2	
Tester Modem	version 2.0.1	
Certification Test Procedures	version 6.04	06/09/2022



Certification Profile **A (CENELEC A)**
 Role **Data Concentrator**
 Overall Verdict **PASS**

Initiation	Date	Description of modification	Ed.
Omar DIOUF	June 5, 2024	Creation	00

	Realised by	Checked by	Approved by
Name	Omar DIOUF	Vincent BUCHOUX	Thierry DOLIGEZ
Date	June 5, 2024	June 5, 2024	June 5, 2024

Sign			
			

The current report and the test results produced in this current are given for information only and must not be relied on by any third person for any reason.
 This report contains an assessment of the apparatus carried out on samples submitted to the laboratory. The results in this report relate only to the items tested and were obtained in the period between the initial receipt of samples and the issue of the report. It should be noted that technical hardware or software modifications on the apparatus may impact the results reported in this document.

MD