



## G3-PLC 500 kHz for Smart Metering

Dr. Michael Koch

Vice President Strategic Positioning

***devolo***  
The Network Innovation

# From the startup to the worldwide market leader in powerline solutions

## devolo AG, Germany – subsidiaries

- devolo Asia Consulting Ltd.
- devolo Austria GmbH
- devolo Benelux bvba
- devolo France SARL
- devolo Schweiz GmbH
- devolo Spain SL
- devolo UK Ltd.

## Further focused sales areas

- Italy, Portugal, Poland,  
Greece and Scandinavia  
(SE, NO, FI, DK, IS)
- Others currently under  
development



# Three business units for the future

*devolo*

2013

2014

2015

**Smart Grid**

B2B

**Home Control**


B2C / B2B

**Home Networking**

B2C / B2B


# Smart Metering Szenario

Typical application of the Access PLC for the Smart Grid Scenarios




# Comparison of PLC Technologies


- + already available as PLC EMC standard: EN 50065
- + separate frequency band for energy supply company and private use
- low data rates
  - small frequency spectrum for PLC transmission
  - poor transmission channels as general EMC filtering is only above 150 kHz
- interaction with other devices, such as e.g. inverters and capacitive switches



- + high data rates
  - range ideal for in-house transmission, insufficient in the access area
  - the need for repeaters harms business plans
- devolo's concept for in-house PLC



- + high coverage and long range: longest transmission distance 1.7 km (measured in field tests; limited by infrastructure)
  - + significantly higher data rate compared to CENELEC band, but lower than in the band above medium wave radio broadcast
- devolo's concept for IP-based communication in PLC Access Networks/Smart Grid applications



# G3-PLC road to an international standard



2008  
2009

- May 2008: International contest for the design of G3-PLC (Launched by ERDF)
- Oct 2009: G3-PLC first field tests on 5 nodes – Presentation of the results at Metering Barcelona

2010  
2011

- Sep 2011: Creation of the G3-PLC Alliance with 12 founding members
- Dec 2011: G3-PLC ITU standard – G9955 and G9956
- Successful interoperability tests

2012  
2013

- G3-PLC ITU T standard – New version G 9903 (Cenelec A, FCC, ARIB)
- Clarifications and enhancement brought by IOT
- Development of the certification processes


2014

- Feb 2014: First interim certificates, Arrib band
- Apr 2014: G3-PLC ITU Standard (Cenelec A, FCC, ARIB)
- Aug 2014: Official certification

# IP-Access Powerline for Smart Grids

Field trials by Vattenfall and devolo in Hamburg and Berlin

*devolo*




- IP-based PLC in real time
- High- speed with long distances by usage 150- 500 kHz
- Fast, reliable performance


## GOALS OF TEST

- Determination of round trip delay time
- Determination of bandwidth in the physical layer
- Calculation of bandwidth in the application layer
- Accessibility of the nodes
- Channel measurement
- Analysis of the lead time for parametrizing and firmware upload to the meters

## DESCRIPTION OF ENVIRONMENT

- Typical environment of urban grid
- High concentrated grid
- Distance between the nodes: min. 200 m
- Installation of one access point in a substation
- Installation of 22 nodes at costumers' premises
- Test only with synthetic data





## PLEASE NOTE:

Achieved data rates are on application layer - physical layer data rates are nominally much higher.

# G3-PLC based Fieldtrials with Vattenfall

## Berlin Trials

- Aim

Evaluation of data rates, distances and channel characterization of G3-PLC 500k in areas where CENELEC-PLC failed due to difficult power grid conditions.



- Locations

- Berlin, Märkisches Viertel: Extensive domestic complex.
- Berlin, Hohenschönhausen: Multi dwelling unit
- Berlin, Kaulsdorf: Low voltage overhead wire.



Märkisches Viertel



Hohenschönhausen



Kaulsdorf

- Results

- Stable communication connections
- Data rates of up to 70 kBit/s payload UDP
- The achieved distances were by far longer than expected.


**Next step: >1000 industrialized products will be tested in the biggest two cities of Germany (Berlin, Hamburg)!**

# G3-PLC based Fieldtrials with Vattenfall – Berlin Results

Flat buildings with 20 floors



		Meter 1	Meter 2	Meter 3	Meter 4	Meter 5	Meter 6
Throughput [kBit/s]	max:	84	83	82	79	81	82
	avg:	79	81	76	73	53	77
	min:	60	74	56	45	22	59
Round Trip Delay [ms]	max:	513	469	474	503	1267	574
	avg:	433	426	437	448	650	441
	min:	418	417	427	426	490	419




# System requirements of the Commission

Recommendation of 9.3.2012, C(2012) 1342 on preparations for the roll out of smart metering systems

- (10) ***Data protection and information security features should be built into smart metering systems before they are rolled out and used extensively.*** Such features can effectively improve consumers' control over the processing of personal data.
  - (11) ... to stimulate and support introduction of the '***security and data protection by design***' principle at an early stage in the development of smart grids, particularly ***for the roll-out of smart metering systems.***
  - (15) ***An assessment of the data protection impact carried out by the operator*** and stakeholders prior to the roll-out of smart metering systems will provide the information necessary in order to take appropriate protective measures. Such measures should ***be monitored and reviewed throughout the lifetime of the smart meter.***
- **German concept: Introduction of a Smart Meter Gateway (SMGW)**

# Overview of Smart Metering System in Germany



Security and Privacy are ensured by the Smart Meter Gateway

- Protection of confidentiality, authentication, integrity of data
- End-to-End Security
- Information flow control

→ Requirement for higher data rates than without security/protection

- devolo's access technology approach based on G3-PLC 150-500 kHz has a very high potential as communication infrastructure for smart metering systems and other Smart Grid applications
  - Support of IP-traffic
  - Data rates observed during the field trials are typically higher than 50 kBit/s (payload TCP)
  - This is above present estimations for data rates requirements for metering systems and Smart Grid application.
  - With it's coverage and the observed distances, repeaters are generally not necessary.
  - Data transmission is robust against interferences on the power grid.
  - No interferences have been observed against other systems.
- System requirements on security and data protections increase data rates requirements.
  - CENELEC PLC systems cannot meet these requirements.

**Next step: >1000 industrialized products will be tested in the biggest two cities of Germany (Berlin, Hamburg)!**

# devolo G3-PLC Modem 500k

Reliable data transmission in Smart Grids

*devolo*

**G3-Powerline technology for efficient communication on smart grids.**

G3-PLC uses your existing power grid to transmit data from smart meters, infeed renewable energy sources and grid status measurement.

Powerline is the essential technology to build up a smart grid in your municipality.



„We have extensively tested devolo’s G3-PLC Modem 500k prototype. Our expectations have been greatly surpassed. That’s why we run a large field test with devolo’s serial product.“

**Jan-Philipp Blenk**

Project Manager Vattenfall Europe Metering GmbH



**Thank you very much  
for your attention.**

Dr. Michael Koch  
Phone +49 241 18279 160  
Mobile +49 151 544 31627  
Michael.Koch@devolo.de

***devolo***  
*The Network Innovation*