

G3-PLC in Eskom

Shawn Papi

30 March 2023



 GENERATION CAPACITY	 TRANSMISSION	 DISTRIBUTION
30 power stations	Transmission lines	Distribution lines
Total nominal capacity of	33 158km	47 809km
46 466MW	Transformer capacity	Reticulation lines
Base-load stations	154 500MVA	310 290km
Coal-fired stations	Grids	8 288km
38 773MW	9	Customers
Nuclear power		6.7 million
1 860MW		Operating clusters
Mid-merit and peaking stations		5
Pumped storage		Zones
2 724MW		27
Hydro stations		CNCs
600MW		308
OCGTs		Service hubs
2 409MW		101
Self-dispatching energy		Contact centres
Sere Wind Farm		8
100MW		

- **Eskom** is a South African electricity public utility.
- The company is divided into Generation, Transmission and Distribution divisions, and together Eskom generates approximately 95% of electricity used in South Africa, amounting to ~45% used in Africa.
- Approximately **700 000 G3-PLC devices installed** (~ 500 000 basic prepayment meters and ~200 000 smart prepayment meters)


SOURCE: <https://en.wikipedia.org/wiki/Eskom>, <https://www.eskom.co.za/about-eskom/company-information/>



2016
G3-PLC part of technical specifications for Eskom Smart Prepayment Project in 2016 for rolling out ~36 000 meters

2017
G3-PLC included in Eskom “Basic Prepayment Meter Standard”


2018
G3-PLC part of Eskom “Smart Metering Standard”



Standardization/Adoption mainly driven by:


- Robustness of G3-PLC in comparison to G1-PLC (PLAN) deployed in earlier years!
- Healthy eco-system of both smart and basic prepayment metering products from manufacturers in Africa, Asia and Europe.



Basic and smart prepayment meter installations



Split meter architecture standardization

- CIU needs to be paired to unique meter, and vice versa
- After outage, customer needs immediate access to prepayment data via CIU
(What is the most efficient architecture to rebuild G3-PLC connectivity between CIU and meter?)






... 661.4	BROADCAST	nBox	G3_FCC	0x926a	1 Bytes	BCN REQ	
... 672.5	COORDINATOR	nBox	G3_FCC	0xef52	6 Bytes	BCN PAN_C	
... 677.8		nBox	G3_FCC+ DATA	0x50b1	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 677.9		nBox	G3_FCC+ DATA	0x3437	82 Bytes	LBP	JOINING EAPRes(mes2)
... 697.8		nBox	G3_FCC+ DATA	0xfe92	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 698.0		nBox	G3_FCC+ DATA	0xfe92	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 718.0		nBox	G3_FCC+ DATA	0xcbb7	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 718.2		nBox	G3_FCC+ DATA	0xcbb7	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 738.2		nBox	G3_FCC+ DATA	0x94d8	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 793.4		nBox	G3_FCC+ DATA	0x853a	12 Bytes	LBP	JOINING
... 793.5		nBox	G3_FCC+ DATA	0x856b	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 793.5		nBox	G3_FCC+ DATA	0xefc8	82 Bytes	LBP	JOINING EAPRes(mes2)
... 813.5		nBox	G3_FCC+ DATA	0x0e90	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 833.5		nBox	G3_FCC+ DATA	0x3bb5	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 853.5		nBox	G3_FCC+ DATA	0x64da	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 896.2		nBox	G3_FCC+ DATA	0xb296	12 Bytes	LBP	JOINING
... 896.3		nBox	G3_FCC+ DATA	0x013a	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 896.4		nBox	G3_FCC+ DATA	0x086a	82 Bytes	LBP	JOINING EAPRes(mes2)
... 916.3		nBox	G3_FCC+ DATA	0x03f8	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 936.4		nBox	G3_FCC+ DATA	0x36dd	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 956.4		nBox	G3_FCC+ DATA	0x69b2	42 Bytes	LBP	CHALLENGE EAPReq(mes1)
... 959.5	BROADCAST	nBox	G3_FCC	0x1d80	1 Bytes	BCN REQ	
... 964.1	COORDINATOR	nBox	G3_FCC	0xa68a	6 Bytes	BCN PAN_C	

```

0... .. = Type      : From LBD (0)
.001 ... = Code     : 1 JOINING
... 0000 0000 0000 = Trans. ID : ok (0)
A_LBD   : 095146fffe003199 (095146):FFFE003199
  Embedded EAP Message
    0000 10.. = Code       : Response (2)
    0000 0000 = Identifier  : 0
    .... 0100 0110 = Length : 70
    0010 1111 = Type       : EAP-PSK (47)
    0100 0000 = Flags      : EAP-PSK second message (64)
    EAP-PSK RAND_S : 888d6feb07b79f5ab6c007ca035b1bb5
    EAP-PSK RAND_P : 7e3dcd082d0c0d4ad98c1b4170be8f79
    EAP-PSK MAC_P  : 9ef0bb489592bb695fd6d4769f904f62
    EAP-PSK ID_P   : 139
  > G3 MFR : MAC Footer
  
```

Not EUI-64 format!

- Compliant with G3-PLC specification
- However, number only applicable to Japanese market (not South Africa)



Thank you